

Lead in School Drinking Water Report

Madison Elementary School



Date(s) collected: 2023-02-17

Date(s) analyzed: 2023-03-02

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
36129	Main Building	Fountain - Multi-Level with Bottle Filler	Hallway	To left of main office	Water Bottle Filler	14
36112	Main Building	Sink	East Pod	Next to white board	Tap	3
36126	Main Building	Sink	Intervention Room	Only sink	Tap	2
36106	Main Building	Sink - Multi-Compartment	Kitchen	Kitchen	Tap	2
36117	Main Building	Sink	Room 10	Only sink	Water Fountain	1
36123	Main Building	Sink	Room 12	Only sink	Water Fountain	1
36107	Main Building	Sink	Kitchen	Pot filler next to fridge	Tap	1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
36139	Main Building	Sink	Room 3	2 tier sink with fountain	Tap	1
36127	Main Building	Fountain - Multi-Level with Bottle Filler	Hallway	To left of main office	Water Fountain	1
36133	Main Building	Sink	Room 2	Only sink	Tap	1
36118	Main Building	Sink	Room 11	Only sink	Tap	1
36105	Main Building	Sink - Multi-Compartment	Kitchen	Largest 3 tier sink	Sprayer	1
36111	Main Building	Fountain - Multi-Level	Hallway	Next to multipurpose. Higher fountain	Water Fountain	1
36134	Main Building	Sink	Room 2	Only sink	Water Fountain	<1
36137	Main Building	Sink	West Pod	Sink in between classrooms	Tap	<1
36131	Main Building	Sink	Room 6	Only sink	Tap	<1
36132	Main Building	Sink	Room 6	Only sink	Water Fountain	<1
36110	Main Building	Fountain - Multi-Level	Hallway	1m between restrooms. Next to multipurpose. Lower fountain	Water Fountain	<1
36116	Main Building	Sink	Room 10	Only sink	Tap	<1
36142	Main Building	Sink	Room 4	Only sink	Water Fountain	<1
36119	Main Building	Sink	Room 11	Only sink	Water Fountain	<1
36122	Main Building	Sink	Room 12	Only sink	Tap	<1
36124	Main Building	Sink	Room 7	Only sink	Tap	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
36108	Main Building	Fountain	Outside. Play Shed	Only fountain outside	Water Fountain	<1
36113	Main Building	Sink	East Pod	Next to whiteboard	Water Fountain	<1
36115	Main Building	Sink	Room 9	Only sink	Water Fountain	<1
36138	Main Building	Sink	West Pod	Sink in between classrooms	Water Fountain	<1
36141	Main Building	Sink	Room 4	Only sink	Tap	<1
36121	Main Building	Sink	Room 8	Only sink	Water Fountain	<1
36128	Main Building	Fountain - Multi-Level with Bottle Filler	Hallway	To left of main office	Water Fountain	<1
36130	Main Building	Sink	Room 1	Only sink	Tap	<1
36114	Main Building	Sink	Room 9	Only sink	Tap	<1
36135	Main Building	Sink	Room 5	Only sink	Tap	<1
36136	Main Building	Sink	Room 5	Only sink	Water Fountain	<1
36140	Main Building	Sink	Room 3	2 tier sink with fountain	Water Fountain	<1
36120	Main Building	Sink	Room 8	Only sink	Tap	<1
36125	Main Building	Sink	Room 7	Only sink	Water Fountain	<1
36104	Main Building	Sink	Kitchen	First sink on left when entering	Sprayer	<1
36109	Main Building	Fountain	Gymnasium	Across from stage on wall	Water Fountain	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**